



GW-7228

J1939/Modbus RTU Slave Gateway

■ Features

- Provide PWR / J1939 / MODBUS indication LED
- Built-in jumper to select 120 ohm terminal resister
- Watchdog inside
- Transmission and reception of all types of J1939 messages, including PDU1, PDU2, broadcast and destination specific
- J1939 Transport Protocol for transmission and reception of large messages (9 - 1785 bytes)
- Support BAM of Connection Management Message
- Network addresses management
- Support RS-232, RS-485 and RS-422 interfaces
- Support Modbus RTU slave protocol
- Configurable for Modbus Network ID(1~250)









■ Introduction


The GW-7228 is a solution that provides a protocol conversion between J1939 and Modbus RTU. For J1939 network, the GW-7228 supports PDU1, PDU2, broadcast and destination specific type of J1939 messages. From the view of Modbus RTU network, the GW-7228 is a Modbus RTU slave to reply the request from Modbus RTU master. We provide Utility software for users to configure the parameters of J1939 / Modbus RTU of the GW-7228. The application fields can be Diesel power-train applications, In-Vehicle networks for trucks and buses, etc.

Hardware Specifications

Hardware	
1	
Microprocessor inside with 96 MHz	
NXP 82C250	
9-pin D-sub connector	
250k	
3000 V _{DC} power protection on CAN side, 2500Vrms photo-couple isolation on CAN bus	
Selectable 120Ω terminal resistor by jumper	
ISO-11898-2, CAN 2.0A and CAN 2.0B	
C.I.A. DS-102 (CAN_H=7, CAN_L=2)	
14-pin screw terminal connecter	
RS-232(TXD, RXD, GND) / RS-422(Tx+, Tx-, Rx+, Rx-) / RS-485(D+, D-)	
2400, 4800, 9600, 19200, 38400, 57600, 115200	
PWR / J1939 / MODBUS	
+10 ~ +30 V _{DC}	
1.5 W	
Init (Firmware Update) / Normal (Firmware Operation)	
DIN-Rail	
108mm x 72mm x 35mm (H x W x D)	
-25 ~ 75 ℃	
-30 ~ 80 ℃	
10 ~ 90% RH, non-condensing	


ICP DAS CO., LTD Website: http://www.icpdas.com Vol. 2020.05 1/2

■ Block Diagram




Utility Features


- · Provide Modbus network configuration interface
- Provide J1939 network configuration interface Network Address / Device Name....
- Provide J1939 Input / Output configuration interface



Wire Assignments



■ Dimensions (Units: mm)



Application



Ordering Information

GW-7228 CR J1939/Modbus RTU Slave Gateway included CA-0910 cable (RoHS)

ICP DAS CO., LTD Website: http://www.icpdas.com Vol. 2020.05 2/2